



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-4314DM0085

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	ENERGY VALVES S.r.l. Via per Olgiate Molgora, 26, I-23883 Beverate di Brivio (LC)
Distributor <i>Vertreiber</i>	ENERGY VALVES S.r.l. Via per Olgiate Molgora, 26, I-23883 Beverate di Brivio (LC)
Product Category <i>Produktart</i>	gas fittings: Shut-off valve for gas transmission >PN 16 (4314)
Product Description <i>Produktbezeichnung</i>	straight pattern ball valve
Model <i>Modell</i>	Floating ball valve
Test Reports <i>Prüfberichte</i>	type testing: 20120217 from 17.02.2021 (TTR)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 14141 (01.08.2013)



7026-04-A-DE

Date of Expiry / File No. 17.02.2026 / 21-0090-GNE
Ablaufdatum / Aktenzeichen

17.03.2021 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Floating ball valve	nominal pressure rating: PN 50/ANSI 300 nominal diameter: DN 15 ambient temperature range: -20...+60 °C	
Floating ball valve	nominal pressure rating: PN 50/ANSI 300 nominal diameter: DN 100 ambient temperature range: -20...+60 °C	

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
DG-5112CQ0189	Elastomer material for seals in gas appliances	N8000 - "FKM 80" BLACK/N8000 - "FKM 80" BLACK	MCM S.p.A.

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

connection: on both sides flange